

# TEST REPORT

**REPORT NUMBER: 170323003SHF-BP-3**

ORIGINAL ISSUE DATE: 2017/4/24

## **EVALUATION CENTER**

Intertek Testing Services Ltd., Shanghai  
Plant 7, No. 6958 Daye Road, Fengxian District, Shanghai, China

## **RENDERED TO**

**ZHANGJIAGANG WELLYOUNG MATERIAL CO. LTD**  
**1501-04, Block A, TIXIANG PLAZA, ZHANGJIAGANG CITY, JIANGSU**  
**PROVINCE, CHINA**

## **PRODUCT EVALUATED**

Magnesium Oxide Board

## **EVALUATION PROPERTY**

As requested by the applicant, for details refer to attached pages(s).

*"This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program."*

Report Template Revision Date: 2016/9/1

## Test Report

Report Number: 170323003SHF-BP-3

Report Date: 2017-04-24

<b>Applicant:</b>	<b>ZHANGJIAGANG WELLYOUNG MATERIAL CO. LTD</b>
<b>Applicant Address:</b>	<b>1501-04, Block A, TIXIANG PLAZA, ZHANGJIAGANG CITY, JIANGSU PROVINCE, CHINA</b>
<b>Attn:</b>	<b>Roger</b>

### Sample information:

Product:	Magnesium Oxide Board
Model:	/
Specification:	12mm thickness
Sample Quantity:	5 pcs
Sample ID:	S170323003SHF-011~015
Date Received:	2017/3/21
Date Test Conducted:	2017/3/23 ~ 2017/4/24

### Conclusion:

For details refer to attached page(s).

The conclusions of this test report may not be used as part of the requirements for Intertek product certification. Authority to Mark must be issued for a product to become certified.



# Test Report

Report Number: 170323003SHF-BP-3

Report Date: 2017-04-24


## Test Items, Method and Results:

ICC-ES AC 386-2007 Acceptance criteria for fiber-reinforced magnesium-oxide-based sheets				
Test item	Test method	Required	Result	Verdict
Nail-head pull through	ASTM D1037-12	$\geq 560\text{N}$	1817 N	Pass

Note:

1. The roofing nail with a 10mm diameter head and a shank diameter of 3mm.

**Appendix A: Sample received photo**



**Approved by:**

Name: Sun Sun  
Title: Approver



Name: Jodie Zhou  
Title: Reviewer

Name: Mason Wang  
Title: Project Engineer

\*\*\*\*\*

The End of Report